

3) Perform household sampling on 20 homes in the Oak Pointe System to evaluate for compliance and notify you, the residents, of the results.

In both June and September 2018, we collected 20 samples each from homes in the Oak Pointe Community, that based on age, had the highest potential to have lead and copper leach from household plumbing. In all samples, copper and lead did not exceed any action levels. In the most recent sample, the highest lead concentration detected was 0.003ppm, with an action level of 0.015 ppm and copper was 0.63 ppm, which is less than 50% of the action level exceedance value of 1.3 ppm. Therefore, all samples are well within acceptable standards.

In addition, recently you may have heard about the concern with Per and Poly fluorinated compounds (PFAS) in drinking water. We are pleased to report that samples collected for the Oak Pointe system were non-detect for any of the PFAS chemicals, which is excellent news for the quality of Oak Pointe drinking water.

We are pleased to report these improved values and improved water quality fully complying with all local and state standards, and we do not anticipate any future problems. If you have any questions or concerns, please contact our office at 810-227-5225.